


Prüflaboratorium Bonn
Hein-Moeller-Str. 7-11
D-53115 Bonn



Test Report

No2016-0139001

Order No	1601621
Customer	apra-norm Elektromechanik GmbH, division apraNET Bei der untersten Mühle 5, D-54552 Mehren, Germany
Manufacturer	apra-norm Elektromechanik GmbH, division apraNET Bei der untersten Mühle 5, D-54552 Mehren, Germany
Specimen	Wall mounting enclosure
Type reference	Vari IT
Date of delivery	2016-08-11
Test Specification	EN 60529:1991 + A1:2000 + A2:2013
Tests conducted	IP4X (1mm test probe), IP5X, cat. 2 (dust chamber) and IPX4 (spray nozzle)
Test results	passed
Number of pages (total)	20 (1 cover sheet 19 documentation sheets - enclosures)
Date of issue	2016-08-25
Signature	 Heribert Schorn Technical Director



The above-mentioned test results refer to the tested specimen only. Uncertainties of measurement resulting from the measuring methods and the test equipment used have been determined and can be provided on request. No part of the present test report shall be copied or duplicated without prior written consent of the Institute for International Product Safety GmbH (I²PS).

This test report is signed electronically. For verification of signature see www.i2ps.de/en. I²PS is a conformity assessment body accredited by the DAkkS Deutsche Akkreditierungsstelle GmbH according to DIN EN ISO/IEC 17025 in the fields of Industrial low-voltage switchgear and controlgear, Assemblies, Electromagnetic Compatibility (EMC) as well as Environmental tests.

LOVAG

The Test Laboratory Bonn of the Institute for International Product Safety GmbH is listed as LOVAG Registered Laboratory under registration code D 01.